

Office of the Incharge District Headquarters Fire Station Officer
(Designated Officer)
Fire & Emergency Services Gandorbal,

The Principal,
Army Goodwill School,
Margund Kangan.

Dated. 11:06:2026.

No: DFO/F-Prv/2026/Gbl/10625

Sub:- Fire & Life safety measures/guidelines in favour of "Army Goodwill School" situated at Margund Kangan.

Ref: - Your online application submission date, 09-05-2026 tracking id. FI026-62845843

Sir,

Kindly refer to the above cited online application under reference regarding the subject mentioned above. In this connection, the inspection of above said school was got carried out by the inspecting officer of this department & found that the management has installed 08 units of ABC type 06 kg, 03 units of water type 09 liters capacity as first aid fire suppression medium in their school premises. However, the site is 08 Km away from Fire & Emergency Station Kangan and is accessible for fire appliance. Since the school is already functioning in 01 double & 03 single storeyed buildings, as such the management can proceed ahead for operation provisionally subject to strictly adopt the following fire safety measures/guidelines in letter and spirit forthwith for the safety of students studying there:-

1. 02 No's water type 09 liters capacity fire extinguishers shall be provided in each floor of all the buildings, 01 No. Each of CO2 type 4.5 kg capacity fire extinguishers shall be provided near electric panel switch board and in computer lab, in addition to already existing fire extinguishers.
2. 01 Hose Reel shall be installed at such a place where from every nook & corner of the all structures are covered easily at the time of any emergency. A Fire booster Pump of desired capacity having 450 LPM discharge shall be installed near terrace water storage tank with dual electric supply for feeding the Hose reel.
3. Wooden components of the structure especially in attic portion shall be given fire retardant treatment of at least two hours rating.
4. All exits/entrances shall be kept open and free from any obstruction for easy and safe evacuation of inmates during any emergency. The corridor of the building shall not be used for any kind of storage.
5. First Aid Fire fighting system installed in the school buildings shall be checked periodically. Staff and students shall be fully trained in handling/operating of fire fighting system installed in the school building.
6. No Hazardous material shall be kept inside of the school premises (especially LPG cylinder, Petrol, Diesel and Central Heating System etc.) Any deviation found in this regard, these fire safety measures/guidelines issued will be treated automatically withdrawn/cancelled.
7. The Management of the school shall be wholly and solely responsible for keeping the fire fighting system in working condition 24x7 and safe evacuation of its students during any mishap.
8. Class/Halls have a capacity of more than 45 students shall have two exits. Grill fitted in the windows shall be removed. Fire/Evacuation drill shall be conducted regularly. Employees of the school shall be trained for maintenance & use of Fire Fighting facilities.
9. At present school is functional in 04 structures, 1. Is double storeyed CGI sheet roofed over wooden truss having single staircase. There are 06 rooms in each floor of the building, 03 single storeyed buildings comprises of 02 halls and 02 rooms in total, As such no addition/alteration shall be made by the school management in the existing structure without prior information from this department. Any deviation found in this regard, these fire safety measures/guidelines will be treated automatically withdrawn/cancelled.
10. An additional staircase of 1.5 meter wide well away from the existing exit shall be provided in the double storeyed school building.
11. The department can make a surprise visit to your school at any time. During the visit if the fire fighting system (i.e. existing as well as proposed) found defunct and deviation, these fire safety measures/guidelines issued shall be treated automatically withdrawn/cancelled.
12. The students of preschool, kindergarten, up to class 1st shall be accommodated on ground floor and class 2nd students shall be accommodated not above 1st floor of the building.
13. **These fire & life safety measures/guidelines shall be subject to outcome of any dispute/investigation enquiry/trial if any pending before any court of Law/investigation agency. These fire & life safety measures/guidelines shall not confirm any title upon the person/company in whose favour it is issued. Furthermore the status with regards to land shall be the responsibility of the concerned registering authority.**
14. **The instant fire safety measures is strictly for adoption of fire safety recommendations/guidelines of the occupancy only and not for authentication of any other claim.**
15. **While issuing final registration /permission to above said establishment, the authority concerned may ensure the fire safety recommendation/guidelines given to the school by this department are fully complied with.**

16. These fire & life safety measures/guidelines are issued in respect of the institution with a validity of two years for adoption & same needs to be renewed after inspection/checking of entire fire fighting system installed in the school (i.e. existing as well as proposed by the technical officer of this department. However, before granting permission/recognition/extension or renewal thereof, the competent authority shall satisfy himself in terms of conditions laid down in SRO-123 of 2010 & SRO-292 of 2018, issued by Education Department with regard to Physical facilities.

Yours Faithfully,



Incharge

District Headquarters,
Fire & Emergency Services Ganderbal.